

UST Program - Statistics

Underground Storage Tank SemiAnnual Report January 1, 2008 through June 30, 2008

I	Regulated Facilities	15,184
II	Active & Closed Petroleum UST Systems	163,776
III	Active & Closed Hazardous Substance UST Systems	23,767
IV	UST Facilities Inspected During Period	8,142
	4a In Significant Operational Compliance with Release Detection Requirements only	642 (7.9%)
	4b In Significant Operational Compliance with Release Prevention Requirements only	951 (11.7%)
	4c In Significant Operational Compliance with BOTH Release Detection and Prevention Requirements	5,980 (73.4%)
	4d In Significant Operational Compliance with neither Release Detection and Prevention Requirements	569 (7.0 %)

This information is provided on a semiannual basis to the State Water Resources Control Board by the local agencies implementing the California underground storage tank requirements.

(updated 12/11/08)